
# SKUNK™ INSTALLATION TOP VIEW DETAIL (TYP)

## SKUNK™ INSTALLATION

#### PROFILE VIEW DETAIL (TYP)




	<u> </u>			٠		
	4	24'	<u>'</u> →	1		
	4				4	— ∨ENT — SKUNK™
	$\Rightarrow$		Height			$\Rightarrow$
	. 4		<u> </u>	12" - 18"	4	
	۵					Sump Depth See Table I
in mp leter						
Dia.		1	4	Δ	4	

Skunk Model	Outlet Pipe Inside Diameter	Skunk Height	Skunk Width	Skunk Depth	Min Sump Depth	Min Sump Diameter
Skunk 10-18	10 to 18"	3'-0"	2'-6"	~ 17"	4' Deep	48" D <b>i</b> a.
Skunk 21-24	21 to 24"	3'-8"	3'-0"	~ 23"	5' Deep	60" Dia.
Skunk 27-30	27 to 30"	4'-0"	3'-10"	~ 26"	5' Deep	72" Dia.
Skunk 36	36"	5'-0"	4'-7"	~ 30"	6' Deep	84" Dia.

Note: Skunk Depth varies depending on Sump Diameter

#### NOTES:

- 1) THE SKUNK™ WILL TRAP FLOATABLE DEBRIS AND LIQUIDS IN A SUMP STRUCTURE. IT CONSISTS OF 3 PANELS THAT MAY BE ASSEMBLED AND INSTALLED BEFORE OR AFTER SUMP STRUCTURE IS SEALED OFF. ALL SKUNK™ PARTS FIT THROUGH A MANHOLE ACCESS WITH A MINIMUM WIDTH OF 24".
- CONTRACTOR MUST VERIFY LOCATION OF CASTING AND STEPS PRIOR TO INSTALLATION OF STRUCTURE.
- 3) THIS GENERIC DETAIL DOES NOT ENCOMPASS THE SIZING, FIT, AND APPLICABILITY OF THE SKUNK™ FOR THIS SPECIFIC PROJECT. IT IS THE ULTIMATE RESPONSIBILITY OF THE DESIGN ENGINEER TO ASSURE THAT THE DESIGN IS IN COMPLIANCE WITH ALL APPLICABLE LAWS AND REGULATIONS. THE SKUNK™ IS A PATENTED TECHNOLOGY OF UPSTREAM TECHNOLOGIES, INC. UPSTREAM TECHNOLOGIES DOES NOT APPROVE PLANS, BUT WILL ASSIST IN SIZING AND DESIGN. GIVE US A CALL AT 651-237-5123.



### SKUNK™ ASSEMBLY

NOT TO SCALE



SKUNK™ STANDARD DETAIL UPSTREAM TECHNOLOGIES INC. 5201 EAST RIVER ROAD, STE. 303 FRIDLEY, MN 55421 651-237-5123

US Patent No. 10,408,242 B1

Rev H (04-24-2023)